

Furnizor: **Sc Trivolt Distribution SRL**
Reg. com.: J23/3300/2016
CIF: RO36421140
Adresa: Strada Apusului nr 3 (primul
sens giratoriu Tehodor Pallady-
Autostrada Soarelui), Catelu, Ilfov
Banca: BRD
IBAN: RO34BRDE441SV13182234410

ERSE CABLU RE-Y(ST)YSWAY- FL TIMF 16 X 3 X 1.3, ERSE

Construc?ie

1. CONDUCTOR IEC-60228, VDE 0295, EN 60228
2. IZOLARE EN 50290-2-1 PVC combinate
3. Codul culorilor BS-5308 PARTEA A-2 sau negru-alb ?i ro?u;
4. INDIVIDUAL SCREEN PSE TAPE, cupru cositorit DRAIN WIRE
6. Placarea cu band? de PES
7. GENERAL SCREEN cupru cositorit DRAIN fir; TAPE AL-PES
8. INNER MANTAU A EN 50290-2-22 PVC combinate
9. Armour GALVANIZAT sârme de o?el ROTUNDE
10. MANTAU A EN 50290-2-22 PVC combinate
11. MANTAU A CULOARE RAL 5015 * BLUE; RAL 9005 * BLACK

cei care nu

- Foarte bine EMC * CARACTERISTICI
- POTRIVIT PENTRU Burry LA SUBTERANE
- FLAME RETARDANT ?i rezistent HIDROCARBURI

Locuri in care rezistenta UV ESTE NECESAR?

Caracteristici tehnice

1. Rezisten?a conductorului (MAX) 0.50 mm² = 36 Ω / km

0,75 mm² = 24.5 Ω / km

1,0 mm² = 18.1 Ω / km

1.30 mm² = 13.9 Ω / km

1,5 mm² = 12.1 Ω ?? / km

2. Rezisten?a de izola?ie (min) 100 MΩXKm

3. CAPACITATE MUTUAL (MAX) 0.50 mm² = 160 pF / m

0,75 mm² = 160 pF / m

1,0 mm² = 160 pF / m

1,30 mm² = 170 pF / m

1,5 mm² = 170 pF / m

4. Gam? de temperatur? - 30 ° C ~ +70 ° C (de stabilire a fixe)

5. FLACARA TEST IEC 60332-3-24; VDE 0482-266-2-4

RO 50266-2-4/BS EN 50266-2-4

6. L / R (raport) (MAX) 0.50 mm² = 25 mH / Ω

0,75 mm² = 25 mH / Ω

1,0 mm² = 25 mH / Ω

1.30 mm² = 40 mH / Ω

1.50 mm² = 40 mH / Ω

7. Curentul de sarcin? (25 ° C) 0.50 mm² = 6,0 A

0,75 mm² = 13 A

1,0 mm² = 16 A

1,30 mm² = 18 A

1,5 mm² = 20 A

8. Tensiunea de lucru 300/500 V.

9. TEST VOLTAJGE Core / Core = 2,000 V.

Core / Ecran = 2,000 V.

10. Indoire 10X cablu Ø

Pret: 0,00 lei (TVA inclus)

Detalii online: <https://www.materialeelectrice.ro/cablu-re-y-st-ysway-fl-timf-16-x-3-x-1-3-erse>

