

Furnizor: **Sc Trivolt Distribution SRL**
Reg. com.: J23/3300/2016
CIF: RO36421140
Adresa: Strada Apusului nr 3 (primul
sens giratoriu Tehodor Pallady-
Autostrada Soarelui), Catelu, Ilfov
Banca: BRD
IBAN: RO34BRDE441SV13182234410

	<u>ERSE CABLU RE-2Y(ST)H (MULTICORE) 7 X 1.5 , ERSE</u> Construc?ie 1. CONDUCTOR IEC-60228, VDE 0295, EN 60228 2. IZOLARE EN 50290-2-23 PE COMPONENTE 3. COD CORES Culoare Alb izolate cu negru 5. Placarea cu band? de PES 6. GENERAL SCREEN cupru cositorit DRAIN fir; TAPE AL-PES 7. MANTAU EN 50290-2-27 LZSH COMBINE 8. MANTAU CULOARE RAL 5015 * BLUE; RAL 9005 * SAU NEGRU RAL 7001 GREY * * CARACTERISTICI RETARDANT flac?r? ?i REZISTENT LA HIDROCARBURI Raza de ?ndoire MICI Fumigen F?R? otrav? si Gaze COROZIVE Caracteristici tehnice 1. Rezisten?a conductorului (MAX) 0.50 mm² = 36 Ω / km 0.75 mm² = 24.5 Ω / km 1.0 mm² = 18.1 Ω / km 1.5 mm² = 12.1 Ω / km 2.5 mm² = 7.41 Ω / km 2. Rezisten?a de izola?ie (MIN) 5000 MΩXKm 3. CAPACITATE MUTUAL (MAX) 0.50 mm² = 115 pF / m 0.75 mm² = 115 pF / m 1.0 mm² = 115 pF / m 1.5 mm² = 115 pF / m 2.5 mm² = 115 pF / m 4. Gam? de temperatur? - 30 ° C ~ +70 ° C (de stabilire a fixe) 5. L / R (raport) (MAX) 0.50 mm² = 25 mH / Ω 0.75 mm² = 25 mH / Ω 1.0 mm² = 25 mH / Ω 1.5 mm² = 40 mH / Ω 2.5 mm² = 60 mH / Ω 6. Curentul de sarcin? (25 ° C) 0.50 mm² = 6,0 A 0.75 mm² = 13 A 1.0 mm² = 16 A 1.5 mm² = 20 A 2.5 mm² = 25 A 7. Tensiunea de lucru 300/500 V. 8. TEST VOLTAJGE Core / Core = 2,000 V. Core / Ecran = 2,000 V. 9. Raza de ?ndoire 7.5X cablu Ø 10. FLACARA TEST IEC 60332-3-24; VDE 0482-266-2-4 RO 50266-2-4/BS EN 50266-2-4 11. FUM DENSITATE IEC 61034-2/VDE 0482-1034-2 RO 61034-2/BS EN 61034-2 12. Test pe corozivitatea gaze de ardere IEC 60754-2/VDE 0482-267-2-3 RO 50267-2-3/BS EN 50267-2-3 13. TEST f?r? halogen IEC 60754-1, VDE 0482-267-2-1 RO 50267-2-1/BS EN 50267-2-1 Pret: 0,00 lei (TVA inclus) Detalii online: https://www.materialeelectrice.ro/cablu-re-2y-st-h-multicore-7-x-1-5-erse
--	--