

Furnizor: **Sc Trivolt Distribution SRL**
Reg. com.: J23/3300/2016
CIF: RO36421140
Adresa: Strada Apusului nr 3 (primul
sens giratoriu Tehodor Pallady-
Autostrada Soarelui), Catelu, Ilfov
Banca: BRD
IBAN: RO34BRDE441SV13182234410

ERSE CABLU RE-2Y(ST)H-TIMF 12 X 3 X 1.3 , ERSE



Construc?ie

1. CONDUCTOR IEC-60228, VDE 0295, EN 60228
2. IZOLARE EN 50290-2-23 PE COMPONENTE
3. Codul culorilor BS-5308 PARTEA-1 sau negru-alb-RED
6. Placarea cu band? de PES
7. GENERAL SCREEN cupru cositorit DRAIN fir; TAPE AL-PES
8. MANTAUA EN 50290-2-27 LZSH COMBIMATE
9. MANTAUA CULOARE RAL 5015 * BLUE; RAL 7001 GREY *

CARACTERISTICI

RETARDANT flac?r? ?i
REZISTENT LA HIDROCARBURI
Raza de ?ndoire MICI

Fumigen

F?R? otravit si

gaze COROZIVE

Caracteristici tehnice

1. Rezisten?a conductorului (MAX) 0.50 mm² = 36 Ω / km
- 0,75 mm² = 24.5 Ω / km
- 1,0 mm² = 18.1 Ω / km
- 1.30 mm² = 13.9 Ω / km
- 1,5 mm² = 12.1 Ω / km
2. Rezisten?a de izola?ie (MIN) 5000 M Ω XKm
3. CAPACITATE MUTUAL (MAX) 0,50 mm² = 100 pF / m
- 0,75 mm² = 100 pF / m
- 1,0 mm² = 100 pF / m
- 1,30 mm² = 100 pF / m
- 1,5 mm² = 100 pF / m
4. Gam? de temperatur? - 30 ° C ~ +70 ° C (de stabilire a fixe)
5. L / R (raport) (MAX) 0.50 mm² = 25 mH / Ω
- 0,75 mm² = 25 mH / Ω
- 1,0 mm² = 25 mH / Ω
- 1.30 mm² = 40 mH / Ω
- 1,5 mm² = 40 mH / Ω
6. Curentul de sarcin? (25 ° C) 0.50 mm² = 6,0 A
- 0,75 mm² = 13 A
- 1,0 mm² = 16 A
- 1,30 mm² = 18 A
- 1,5 mm² = 20 A
7. Tensiunea de lucru 300/500 V.
8. TEST VOLTAJGE Core / Core = 2,000 V.
- Core / Ecran = 2,000 V.
9. Raza de ?ndoire 7.5X cablu $\emptyset$
10. FLACARA TEST IEC 60332-3-24; VDE 0482-266-2-4
- RO 50266-2-4/BS EN 50266-2-4
11. FUM DENSITATE IEC 61034-2/VDE 0482-1034-2
- RO 61034-2/BS EN 61034-2
12. Test pe corozivitatea gaze de ardere IEC 60754-2/VDE 0482-267-2-3
- RO 50267-2-3/BS EN 50267-2-3
13. TEST f?r? halogen IEC 60754-1, VDE 0482-267-2-1
- RO 50267-2-1/BS EN 50267-2-1

Pret: 0,00 lei (TVA inclus)

Detalii online: <https://www.materialeelectrice.ro/cablu-re-2y-st-h-timf-12-x-3-x-1-3-erse>