

Furnizor: **Sc Trivolt Distribution SRL**
Reg. com.: J23/3300/2016
CIF: RO36421140
Adresa: Strada Apusului nr 3 (primul
sens giratoriu Tehodor Pallady-
Autostrada Soarelui), Catelu, Ilfov
Banca: BRD
IBAN: RO34BRDE441SV13182234410



LEGRAND TRANSFORMATOR DE SEMNAL SI CONTROL - 1 PH - PRIM
460 V SEC 115/230 V -2500 VA-SCREW

Caracteristici tehnice

Control and circuit isolation- screw connection

Input Tensiune = 460 V $\pm$ 20 V~ Output Tensiune = 115-230 V~

Supplied with 2 coupling strips

Putere in VA according to IEC and CSA : 2500

Putere in VA according to UL : 1300

Instantaneous admissible Putere at cos ϕ = 0.5 : 7100

Caracteristici generale

Control, safety and circuit isolation transformers - single-phase

IP 2X or XXB up to 400 VA (coupling strip not mounted) - IP XXA over 400 VA - IK 04

Conform to IEC EN 61558-2-2 and 2-4 or 2-6, UL506 and CSA C22-2-No 66

UL USA and Canada agreements

Products suitable for building equipment conforming to standards EN 61131-2, EN 60204-1 and EN 60439-1

Active parts protected by cover up to 1000 VA

Interference filtering (except Cat.Nos 0 442 16/17/18)

Direct fixing possibility on symmetrical rail up to 250 VA

Supplied with coupling strip 0 V secondary / earth up to 1000 VA (except spring connection range)

Pret: 0,00 lei (TVA inclus)

Detalii online: <https://www.materialelectrice.ro/transformator-de-semnal-si-control-1-ph-prim-460-v-sec-115-230-v-2500-v-a-screw-236781>