



Furnizor: **Sc Trivolt Distribution SRL** Reg. com.: J23/3300/2016 CIF: RO36421140 Adresa: Strada Apusului nr 3 ( primul sens giratoriu Tehodor Pallady-Autostrada Soarelui), Catelu, Ilfov Banca: BRD IBAN: RO34BRDE441SV13182234410

IEK SIGURANTA AUTOMATA MCB VA47-29 3P 25A 4,5KA CURBA C
IEK SIGURANTA AUTOMATA MCB VA47-29 3P 25A 4,5KA CURBA C Modular circuit breakers (MCB) VA47-29 are intended for protecting distribution and group systems having different loads: - electric appliances, lighting - B characteristic switches; - drives with moderate starting currents (compressor, fan group) - C characteristic switches; Modular circuit breakers VA47-29 are recommended for use in electrical distribution panels of residential and public buildings. Two types of protection against overloads and short circuit. Complete set of supplementary devices with the possibility of simple independent installation: - State contact KS47; - State contact KS47; - Undervoltage trip RMM47; - Low-voltage release RN47. Improved arc suppression system: extended service life, increased resistance to short- circuit currents. Contact position indicator. Wide operating temperature range from -40 to +50° Đ <sub>1</sub> . Simultaneous connection by FORK bar and flexible conductor is possible for power supply distribution via upper terminals, as well as connection by PIN bar. New ergonomic design of ON/OFF lever. Notched terminal clamps reduce the heat loss and increase mechanical stability of the connection.Number of poles: 3 Primary current: 25 Release characteristic: EV00084 Nominal operating voltage: 400 Rated short-circuit breaking capacity EN 60898: 4,5 Width in number of modular spacings: 3 Max. cross section incoming cable: 25 Nominal voltage DC: 4 48 Rated surge voltage invariability: 4 Current limiting class: 3 Frequency: 50 Frequency: 50 Frequency: 50 Degree of protection (IP): EV006405 Ambient class: IEK, V000010 Number of poles (X000010 Number of poles (X000010 Number of poles (X000010 Number of poles (X000010 Number of poles (X000015 Release actuating time in short-circuit tm zone: 0,1 Nominal rated current; 25.0 Nominal rated curent; 25.0 Nominal rated current; 2
Detalii online: https://www.materialeelectrice.ro/siguranta-automata-mcb-va47-29-3p-25a-4-5ka-curba-c-306509