

Furnizor: **Sc Trivolt Distribution SRL**  
Reg. com.: J23/3300/2016  
CIF: RO36421140  
Adresa: Strada Apusului nr 3 ( primul  
sens giratoriu Tehodor Pallady-  
Autostrada Soarelui), Catelu, Ilfov  
Banca: BRD  
IBAN: RO34BRDE441SV13182234410



### **CAVI CABLU NHXH CU INTARZIERE LA FOC, FARA HALOGENURI 12X1,5**

Cablu din cupru cu izolatie rezistenta la foc, fara halogenuri (Halogen Free) .

Caracteristici :

Emisie redusa de fum , fara gaze otravitoare

Bazat pe standarde: VDE 0276-604/VDE 0266 HD 604 S1

Rezistenta la foc 180 minute .Rezistenta in Flacara 90 minute.

Temperatura de lucra -40°C.....+ 90°C

Tensiune 0,6-1KV

|                                 |                                                                            |
|---------------------------------|----------------------------------------------------------------------------|
| 1. FLAME RETARDANT              | IEC 60332-1-2;VDE 0482-332-1-2<br>EN 60332-1-2/BS EN 60332-1-2             |
| 2. FLAME PROPAGATION            | IEC 60332-3-24/<br>VDE 0482-332-3-24<br>EN 60332 -3-24<br>BS EN 60332-3-24 |
| 3. SMOKE DENSITY                | IEC 61034-2 VDE 0482-267-2-3<br>EN 61034-2/BS-EN 61034-2                   |
| 4. CORROSIVE GAS TEST           | IEC 60754-2;VDE 0482-267-2-3<br>EN 50267-2-3/BS EN 50267-2-3               |
| 5. HALOGEN-FREE TEST            | IEC 60754-1;VDE 0482-267-2-1<br>EN 50267-2-1/BS EN 50267-2-1               |
| 6. CIRCUIT INTEGRITY(FE 180)    | IEC 60331-21                                                               |
| 7. CIRCUIT INTEGRITY WITH SHOCK | IEC 60331-21/EN 50363 BS EN 50362 /VDE 0482-362                            |
| 8. SYSTEM CIRCUIT INTEGRITY     | DIN 4102-12(E90                                                            |

Pret: 0,00 lei (TVA inclus)

Detalii online: <https://www.materialeelectrice.ro/cablu-nhxx-cu-intarziere-la-foc-fara-halogenuri-12x1-5>