



### **IEK COINCIDENT CONTACT AKDK-250/400A**

Coincident AK/DK contacts (auxiliary and signal contacts in one casing) are intended for obtaining information on the status of VA88 MCCB contacts and giving out a signal in case of its actuation from overcurrent, shunt trip or undervoltage release. Emergency and auxiliary contact in one housing for the possibility of installing additional accessories. Device fitting: EV000646

Additional equipment: EV009833

Assembly width (TE): -

Number of normally open contacts: 0

Number of normally closed contacts: 0

Number of change-over contacts: 1

Number of contacts as change-over contact: 1

Number of fault-signal switches: 0

Rated switch current: 400

Control voltage type: EV000460

Nominal rated voltage: 230/400

Nominal voltage DC: 220

Voltage type: EV000509

Compliance with current breakers: ??88-35/37

Nominal operating current for 230V AC: 2

Nominal operating current for 230V DC: 6

Nominal operating current for 400V AC: 2

Nominal operating current for 400V DC: 3,5

Nominal operating current for 220V AC: 0,2

Nominal operating current for 220V DC: 0,2

Pret: 128,54 LEI (TVA inclus)

Detalii online: <https://www.materialelectrice.ro/coincident-contact-akdk-250-400a-307475>