



IEK SIGNAL AUXILIARY CONTACT AK-630/800/1600A

Signal auxiliary contact AK is intended for giving out a signal when a circuit breaker actuates from: – overcurrent (overload or short circuit); – shunt trip; – undervoltage trip; – "TEST" button. When the main contacts return to "switch on" position, the signal turns off. Remote alarm notification and status monitoring. Device fitting: EV000646

Additional equipment: EV009833

Assembly width (TE): -

Number of normally open contacts: 0

Number of normally closed contacts: 0

Number of change-over contacts: 1

Number of contacts as change-over contact: 1

Number of fault-signal switches: 0

Rated switch current: 1600

Control voltage type: EV000460

Nominal rated voltage: 230/400

Nominal voltage DC: 220

Voltage type: EV000509

Compliance with current breakers: ??88-40/43

Nominal operating current for 230V AC: 2

Nominal operating current for 400V AC: 2

Nominal operating current for 220V AC: 0,2

Conventional thermal current : 2

Pret: 78,84 LEI (TVA inclus)

Detalii online: <https://www.materialelectrice.ro/signal-auxiliary-contact-ak-630-800-1600a-307625>